



**MINOOKA FIRE  
PROTECTION DISTRICT**  
Fire Prevention Bureau  
Fire Inspector Rodney Bradberry

---

***FIRE COMMAND CENTER  
Plan Review Checklist***

Date: \_\_\_\_\_ Permit Number: \_\_\_\_\_

Business Name: \_\_\_\_\_ Address: \_\_\_\_\_

***The Fire Alarm Command Center shall comply with NFPA 72 and shall contain the following features:***

- The Emergency Voice Communications System.
- The Fire Department Communication System
- Fire detection and alarm system annuciator system.
- Annunciator visually indicating the location of the elevator and whether they are operational.
- Status indicators and controls for air-handling systems.
- The Firefighter's control panel required by this section 909.16 for smoke control systems installed in the building.
- Controls for unlocking stairway doors simultaneously.
- Sprinkler valve and water flow detector display panels.
- Emergency and stand-by power status indicators.
- A telephone for fire department use with controlled access to the public telephone system.
- Fire Pump status indicators.
- Schematic building plans indicating the typical floor plan and detailing the building core, means of egress, fire protection systems, fire-fighting equipment and fire department access.
- Work Table.
- Generator supervision devices, manual start and transfer features.
- Public address system, where specifically required by other sections of this code.

***Fire Command Center Plan Review Results:***

**Approved**

**Not Approved**

**Completed By:** \_\_\_\_\_